

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Polyflor

Radcliffe New Road, Whitefield, Manchester, United Kingdom

For the following product(s):

Vinyl Tile:

Bevel Line PUR, Camaro PUR, Colonia PUR, Expona Commercial PUR, Expona Control PUR, Expona Design PUR, Expona Domestic PUR

This product meets all of the necessary qualifications to be certified for the following claim:

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (effective January 1, 2012) for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Registration # SCS-FS-02385

Valid from: October 1, 2014 to September 30, 2015

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI ACCREDITED PROGRAM
PRODUCT CERTIFICATION
#0821



A handwritten signature in blue ink that reads "Robert J. Hrubes".

Robert J. Hrubes, Ph.D., Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA