

Certificate Indoor Air Comfort Gold



Expona Design, Expona Control, Kudos, Superplank, Bevel Line, Camaro, Colonia

Polyflor Limited, Radcliffe New Road, Whitefield Manchester M45 7NR

The product has undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Comfort Gold certification, version 3.1 (2011). This includes a VOC emission chamber test and an audit of the manufacturing site.

Successful evaluation means:

No carcinogenic substances were detectable above their limit values, including 4 CMR substances regulated in France.

Formaldehyde was below the limit value of 10 μg/m³.

Sum of VOC (TVOC) was below the limit values of 1.000 μg/m³ after 3 days and 160 μg/m³ after 28 days. The product was classified A+ according to French VOC regulation.

Sum of SVOC after 28 days was below the limit value of 30 µg/m³.

Evaluation of individual VOC: R values were below the limit values of 1 for both German NIK and French LCI lists after 28 days. Sums of VOC without German NIK and French LCI both were below 100 μg/m³.

Quality management system and factory production control program at production site complied with the requirements.

Therefore the product qualifies for the Indoor Air Comfort Gold label.

Certificate No.: 2012 - IACG - 43

Date: 06-06-2012 Validity of certificate: 06-06-2013

Director Certification Chemical Safety

General Manager

Eurofins Product Testing A/S Tel. +45 70 22 42 76

ProductTesting@eurofins.com www.product-testing.eurofins.com

Sampling, testing and evaluation were performed according to the standards ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, EN 13419 in the latest versions.