SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Polyflor

Radcliffe New Road, Whitefield, Manchester, United Kingdom

For the following product(s):

Sheet Vinyl:

Acoustix Forest fx PUR, Bloc PUR, Designatex PUR, Expona Flow PUR, Forest fx PUR, Polysafe Stone FX PUR, Polysafe Wood fx Acoustix PUR, Polysafe Wood fx PUR, Secura PUR, Silentflor PUR



The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)



Registration # SCS-FS-02913

Valid from: September 1, 2022 to August 31, 2023

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.



Tranky Mather Kam

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA